

ISO IEC 17025 Accredited Lab

Inspection Body

TL17-70001

1 of 9

LQF-708-02 Review No:06

# EPIL TEST REPORT

Project No.:TL17-70001

Equipment under Test: LOCK OUT RELAY

Model/Type

S/N

Manufactured by: HAMIANFAN Co.

Applicant: HAMIANFAN Co.

Trade Mark:

Tested According to: Client Request

Reception Date of Sample: 17-june-2021

Issue Date: 26-june-2021

**Test Result: PASSED** 

No. of pages: 9

Prepared and Tested by: Fest Engineer

A Bayat

hief Executive Office

S M Mirsadri

Technical Department

150 IEC 17025

Accredited Lab Test results pertain to the tested sample only.

Not Valid Without Lab Stamp.

Approved by:

ELA070 H AUX112070

Testing Date: 22-june-2021

Verified by: Technical Manager

B.Hamidifard

Engineering Deputy Of Test And Inspection

Prof. B. Vanidi

Sofet Dood End. Corner of Fariman St. Bozol

Office: Unit 12, No.2, Boujari Sefat Dead-End, Corner of Fariman St., Bozorgmehr St., Vali-Asr Ave., Tehran-Iran Postal Code: 1416854523 Tel: 021-61971 Fax: 021-66174283

Lab: Kayosh Reaserch City, Supa Blvd., 8<sup>th</sup> km of karaj-Qazvin Freeway, Iran



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body

TL17-70001

2 of 9

LQF-708-02 Review No:06

Contents	·	2
1.	GENERAL INFORMATION	
1.1.	Product Information	
1.2.	Client Information	3
1.3.	Tests Performed	3
1.4.	Results of Tests	3
2.	PERFORMANCE AND RESULTS OF TESTS	4
Ζ.	PERI ORIVINATE MED MED TO	1
2.1.	Function Test	
2.1.1.	Test data	
2.1.2.	Ambient conditions	
2.1.3.	Instrument used for the test	4
	Procedure of test	
2.1.4.		
2.1.5.	Result of test	
3.	FIGURES	7



Energy & Power Industries Laboratories Co.(J.S.)

**ISO IEC 17025 Accredited Lab** 

Inspection Body

LQF-708-02 Review No:06

TL17-70001

3 of 9

### 1. GENERAL INFORMATION

# 1.1. Product Information

Model/Type

S/N

**Nominal Voltage** 

**Operation Voltage** 

Operation Time of Heavy-Duty Contacts for

**52 VDC** 

Operation Time of Heavy-Duty Contacts for

140 VDC

**Details and Drawings** 

**ELA070 H** 

AUX112070

110VDC

35-140VDC

<5ms

<4ms

According to report

# 1.2. Client Information

Main Client

**Contact Person** 

Telephone

Fax

HAMIANFAN CO.

Eng. Araghi

+98-21-88581431-4

+98-21-44725313

# 1.3. Tests Performed

**Function Test** 

**PASSED** 

# 1.4. Results of Tests

See Pages 5-6



ISO IEC 17025 Accredited Lab

Inspection Body

TL17-70001

4 of 9

LQF-708-02 Review No:06

# 2. PERFORMANCE AND RESULTS OF TESTS

# 2.1. Function Test

2.1.1. Test data

Location

Date

**Engineer of EPIL** 

Normative document

Number of samples

E.P.I.L Co.

22-june-2021

Eng. Bayat

Client Request

2

2.1.2. Ambient conditions

**Ambient Temperature** 

"18°C -24°C"

#### 2.1.3. Instrument used for the test

Instrument	Calibration
Multimeter	Ok
DC Voltage Supply(CMC 256)	Ok
Stopwatch	Ok
Oscilloscope	Ok
Relay Tester	Ok

### 2.1.4. Procedure of test

The functions of lock out Relay shall be tested.

When a lock out signal comes, the red LED turns ON, to show trip status, and remains ON, until reset key pushed or remote reset is done. When the relay is not locked out, the red LED is OFF, while the discussed relay is in lock out status, the circuit breaker cannot operate. This relay operates into complex with protective relay. The break contact of protective relay make series with the lock out relay's coil and when this break contact operates, main contact of relay works, this relay is equipped with two possibilities for reset. One by hand reset on relay and other one is electrical reset from control room, Tests shall be conducted to demonstrate the above specifications and functions during the operation voltage range (35 to 140 VOC).



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body

TL17-70001

5 of 9

LQF-708-02 Review No:06

2.1.5. Result of test

Table 1: Result of operation time

Applied Voltage	Breaking Current	Iteration No.	Operation Time	Result
140	breaking carrent	1	< 4 msec	ОК
		2	< 4 msec	ОК
	< 3 A	3	< 4 msec	OK
		4	< 4 msec	OK
		5	< 4 msec	ОК
		1	< 4 msec	OK
		2	< 4 msec	ОК
120	< 3 A	3	< 4 msec	OK
120		4	< 4 msec	OK
4	22	5	< 4 msec	ОК
110		1	< 4 msec	OK
	•	2	< 4 msec	OK
	< 3 A	3	< 4 msec	OK
		4	< 4 msec	ОК
		5	< 4 msec	OK
70	1	1	<5 msec	OK
	Ac	2	<5 msec	OK
	< 3 A	3	<5 msec	OK
		4	<5 msec	OK
		5	<5 msec	ОК
35		1	<5 msec	OK
	11	2	<5 msec	ОК
	<3A	3	<5 msec	OK
	K 57	4 :	<5 msec	OK
		5	<5 msec	OK



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body


LQF-708-02 Review No:06

TL17-70001

6 of 9

Table 2: Results of keeping the contact and LED status

Applied Voltage	Iteration No.	Result
	1	OK
	2	OK
140	. 3	OK
	4	OK
•	. 5	OK
	1	OK     OK     ■ OK
	2	OK
110	3	OK
	4	OK
	5	OK
	. 1	OK
	2	OK OK
80	3	OK
	4	ОК
	5	OK
	1	OK OK
	2	OK
35	3	OK
	4	OK
	5	OK



This relay keeps the contact and LED status after interruptions. The relay is tested under locked out status, and DC tripping circuit it has been removed, the relay remained locked out until reset.

The local and electrical resets have been checked and their performances were OK.

#### ✓ PASSED



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body

TL17-70001

7 of 9

LQF-708-02 Review No:06

### 3. FIGURES




FIGURE 1: EUT connections and terminals



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body

LQF-708-02 Review No:06

TL17-70001

8 of 9




Figure 2: Drawing And dimensions of EUT



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025 Accredited Lab

Inspection Body

LQF-708-02 Review No:06

TL17-70001

9 of 9



Figure 3: The test circuit of measurement of operation time of EUT.